

OFFICE OF CIVILIAN RADIOACTIVE WASTE MANAGEMENT DESIGN CALCULATION OR ANALYSIS COVER SHEET

1. QA: QA
2. Page 1

3. System: Waste Emplacement and Retrieval System	4. Document Identifier: 000-00C-WER0-00100-000-00A	5. Verified: <input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
--	---	---

6. Title:
Subsurface Shielding Source Term Specification Calculation

7. Group:
Nuclear

8. Document Status Designation:

Preliminary
 Final
 Superseded
 Cancelled

9.

T	F	
<input checked="" type="checkbox"/>	<input type="checkbox"/>	1. This product contains no potentially sensitive information.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	2. This product contains information that could define a target.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	3. This product contains information that could define a specific location.
<input type="checkbox"/>	<input checked="" type="checkbox"/>	4. This product contains information that identifies vulnerabilities.

10. Notes/Comments:
All pages are affected, because of the addition of the header and change to the footer on every page. Changes to the documented text are identified by vertical change bars in the left margins. There is no deletion of existing pages. The total page count increases from 49 to 52, as a result of the changes to the documented text.

Attachments	Total Number of Pages
I. Listing of Computer Files	1
II. One Compact Disk Containing All Files Listed in Attachment I (1of 1)	0

RECORD OF REVISIONS

11. No.	12. Reason for Revision	13. Total No. of Pages	14. Last Page No.	15. Originator (Print/Sign)	16. Checker (Print/Sign)	17. Quality Engineering Representative (Print/Sign)	18. Approved/ Accepted (Print/Sign)	19. Date
A	This document supersedes and revises the previous document CAL-WER-NU-000003 REV 00 to remove the unnecessary TBV items, revise the affected calculation, change the input status for certain items, use the current document numbering system and incorporate updates on waste arrival scenarios and reference sources.	52	I-1	S. Su <i>S. Su</i> 12/9/02	G. Radulescu <i>Georgeta Radulescu</i> 12/09/02	D. J. Tunney <i>DJ Tunney</i> 12/9/2002	G. D. Pedersen <i>GDP</i>	12/10/02

CONTENTS

	Page
1. PURPOSE.....	6
2. METHOD	7
3. ASSUMPTIONS	8
4. USE OF COMPUTER SOFTWARE	11
4.1 BASELINE SOFTWARE.....	11
4.1.1 MCNP.....	11
4.1.2 PATH.....	11
4.2 SOFTWARE ROUTINES	11
5. CALCULATION.....	12
5.1 REVIEW AND COMPILATION OF SOURCE TERMS.....	12
5.1.1 PWR SNF	12
5.1.2 BWR SNF.....	15
5.1.3 DHLW	18
5.1.4 DOE SNF.....	18
5.1.5 Naval SNF	18
5.2 REVIEW OF WASTE PACKAGE DOSE RATE CALCULATIONS.....	21
5.3 WASTE STREAM AND FUEL ASSEMBLY HEAT DISTRIBUTION	21
5.4 WASTE PACKAGE THERMAL SOURCE TERMS	26
5.5 SELECTION OF DESIGN BASIS FUEL.....	26
5.5.1 SELECTION METHOD	26
5.5.2 PWR DESIGN BASIS FUEL.....	27
5.6 FUEL ASSEMBLIES CONTRIBUTING TO DOSE RATES.....	30
5.6.1 Calculation Inputs.....	30
5.6.2 PATH Calculation	32
5.7 MCNP CALCULATION FOR HOMOGENIZED MODEL	36
6. RESULTS AND RECOMMENDATIONS.....	40
6.1 WP SPECIFIC SOURCE TERMS	40
6.2 DOSE RATE RESULTS	40
6.2.1 PATH CALCULATION – EXPLICIT FUEL ASSEMBLY MODEL.....	40
6.2.2 PATH CALCULATION – HOMOGENIZED MODEL.....	43
6.2.3 MCNP CALCULATION – HOMOGENIZED MODEL.....	43
6.3 SPECIAL FUEL LOADING CONSIDERATIONS	45
7. REFERENCES	47
7.1 DOCUMENTS CITED.....	47
7.2 PROCEDURES USED.....	50
8. ATTACHMENTS	51

FIGURES

	Page
Figure 1. Heat Distribution of PWR SNF Inventory upon Receipt at Repository.....	24
Figure 2. Explicit Fuel Assembly Model for PATH Calculation	33
Figure 3. Radial WP and Transporter Model for MCNP Calculation	37

TABLES

	Page
Table 1. Maximum and Average PWR SNF Neutron Source Terms	13
Table 2. Maximum and Average PWR SNF Gamma Source Terms	14
Table 3. Maximum and Average BWR SNF Neutron Source Terms.....	16
Table 4. Maximum and Average BWR SNF Gamma Source Terms.....	17
Table 5. Neutron and Gamma Sources per SRP DHLW Glass Canister at Year 2010.1	19
Table 6. Neutron and Gamma Current Sources Exiting Naval Spent Fuel Canister Side Surface	20
Table 7. WP Surface Dose Rate Comparison	22
Table 8. Summary Heat Distribution for PWR Fuel upon Receipt at Repository	23
Table 9. Design Basis PWR SNF Neutron Source Terms	28
Table 10. Design Basis PWR SNF Gamma Source Terms	29
Table 11. Material Compositions of SNF, WP Components, and Shielding Materials.....	31
Table 12. Smeared PWR Fuel Region	34
Table 13. PATH Input and Output Files for Explicit Fuel Assembly Model	35
Table 14. Fuel Region Smeared Composition for MCNP	38
Table 15. PATH Gamma Dose Rate Results for Explicit Fuel Assembly Model	41
Table 16. Identification of Contributing Fuel Assemblies.....	42
Table 17. MCNP Dose Rate Results for Homogenized Fuel Assembly Model	44
Table 18. Comparison of Gamma Dose Rate Results for Different Models	44

ACRONYMS AND ABBREVIATIONS

ANSI	American National Standards Institute
ANS	American Nuclear Society
BSC	Bechtel SAIC Company, LLC
BWR	Boiling Water Reactor
B&W	Babcock & Wilcox
cc or cm ³	cubic centimeters
CFR	Code of Federal Regulations
cm	centimeters
CPU	Central Processing Unit
CRM	Corrosion Resistant Material
CRWMS	Civilian Radioactive Waste Management System
CSCI	Computer Software Configuration Item
DHLW	Defense High-Level Waste
DOE	U.S. Department of Energy
FFTF	Fast Flux Test Facility
g	grams
GWd	Gigawatt Days
hr	hours
ID	Identification
kg	kilograms
kW	kilowatts
MCNP	Monte Carlo N-Particle transport code
MeV	Million Electron Volts
MOX	Mixed Oxide
MTU	Metric Tons of Uranium
M&O	Management and Operating Contractor
n	neutrons
NRC	U.S. Nuclear Regulatory Commission
OFF	Oldest Fuel First
PC	Personal Computer
PWR	Pressurized Water Reactor

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

rad	A radiation dose unit with 1 rad = 100 ergs/g
rem	Roentgen Equivalent in Man
s or sec	seconds
SNF	Spent Nuclear Fuel
SRP	Savannah River Plant
SS	Stainless Steel
TBV	To Be Verified
UCF	Unregistered Fuel
VA	Viability Assessment
W	Watts
WP	Waste Package
YFF	Youngest Fuel First
YMP	Yucca Mountain Site Characterization Project
yr	year
γ	Gammas or photons

1. PURPOSE

This calculation supersedes and revises the previous calculation documented in CAL-WER-NU-000003 REV 00 (BSC 2001e). The purpose of the revision is: (1) to remove the unnecessary To-Be-Verified (TBV) items for standard engineering materials used and revise the affected calculation, (2) change the input status for certain item in accordance with AP-3.15Q, *Managing Technical Product Inputs*, with additional assumptions, (3) use the current document numbering system per *Engineering Standard for Document/Component Numbering*, and (4) incorporate updates on waste arrival scenarios and reference sources.

This calculation establishes appropriate and defensible waste-package radiation source terms for use in repository subsurface shielding design. This calculation supports the preliminary shielding design for the waste emplacement and retrieval system, and subsurface facility system. The objective is to identify the limiting waste package and specify its associated source terms including source strengths and energy spectra. The scope of work includes the following:

- Review source terms generated for Yucca Mountain Site Characterization Project (YMP) for various waste forms and waste package types, and compile them for shielding-specific applications.
- Determine acceptable waste package specific source terms for use in subsurface shielding design, using a reasonable and defensible methodology that is not unduly conservative.

This calculation is associated with the engineering and design activity for the waste emplacement and retrieval system under Work Package P3412233FQ for Fiscal Year 2002. The results are intended for use as a radiation source term specification in the preliminary shielding design for the subsurface systems including the waste package transporter, emplacement/retrieval equipment, and subsurface facility layout associated with waste emplacement/retrieval. The waste package transporter in the waste emplacement and retrieval system is classified as Quality Level 1 (CRWMS M&O 2001, p. 8). Therefore, this calculation is subject to the requirements of the *Quality Assurance Requirements and Description* (DOE 2002). Development and performance of this calculation conforms to the procedure, AP-3.12Q, *Design Calculations and Analyses*.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

2. METHOD

The following step-by-step approach is used to determine the waste package specific source terms for subsurface shielding applications:

- a. Review and compile the source terms generated for YMP for the various waste forms including pressurized water reactor (PWR) spent nuclear fuel (SNF), boiling water reactor (BWR) SNF, defense high-level waste (DHLW), naval reactor SNF, and U.S. Department of Energy (DOE) SNF.
- b. Identify the limiting waste package by comparing the dose rates on the waste package (WP) surfaces calculated for YMP for the different types of waste packages.
- c. Review the *1999 Design Basis Waste Input Report for Commercial Spent Nuclear Fuel* (CRWMS M&O 1999a) on the projected waste streams and fuel assembly heat distributions for selection of the design basis assembly heat and fuel characteristics (initial enrichment, burnup and cooling time). Also, review the *Design Basis Waste Input Assumptions for License Application* (BSC 2001a) to identify potential impacts on the selection of the design basis fuel.
- d. Review the WPD calculation document on *Waste Packages and Source Terms for the Commercial 1999 Design Basis Waste Streams* (CRWMS M&O 2000g) to identify the peak heat fuel assembly in the waste packages received by year. This information is used to determine reasonableness of the design basis fuel selected from Step c on the basis of the assembly heat distribution.
- e. Determine the relative contribution from each individual fuel assembly to the dose rate on the WP surface and transporter surface for evaluation and selection of the fuel loading pattern. The determination considers the gamma contribution only, which is much more significant than the neutron contribution (BSC 2001b, p. 29). The PATH gamma shielding code (Su et al. 1987) is used for this step of the calculation.
- f. Develop and select the geometric model for the design basis fuel, considering the explicit and homogeneous models for the selected fuel loading pattern. Again, this step considers the principal dose component only (i.e., from gamma radiation), and uses the PATH code.
- g. Perform the dose rate calculations for the design basis fuel with the MCNP code (Briesmeister 1997), using the geometric model developed from Step f. Because of the ability of treating detailed particle transport physics, use of the MCNP code produces more accurate results. PATH is useful mainly for scoping or prototypic calculations.

Electronic management of information generated from this calculation is controlled in accordance with AP-3.13Q, *Design Control*. The computer input and output files generated from this calculation are stored on an electronic medium (compact disk), and submitted as an attachment to this document.

Originator: *ML* Date: *12/09/02* Checker: *GR* Date: *12/09/02*
Nuclear Engineering

3. ASSUMPTIONS

The following assumptions are used in this calculation.

- 3.1** For the smeared material calculation, the active fuel region of each SNF assembly contains fresh, unirradiated fuel. This assumption applies to the material composition. By no mean does it apply to the source term, which is based on spent fuel.

Rationale: This assumption is conservative since it leads to slightly higher dose rates. The higher percentage of fissile ^{235}U in each assembly results in a greater number of induced fission neutrons, and consequently a stronger radiation field. No further confirmation of this assumption is required.

Usage: This assumption is used in Section 5.6.1.

- 3.2** Uniform fuel burnup is assumed.

Rationale: The axial fuel burnup profile is not considered here, as the purpose of this calculation is to determine waste package specific source terms rather than shielding requirements. This profile needs to be incorporated into subsequent shielding design in the future. No further confirmation of this assumption is required insofar as this calculation is concerned.

Usage: This assumption applies to the source terms provided in Section 5.5.2.

- 3.3** Internal fuel basket materials are ignored for purposes of smeared material composition. Only the fuel basket corner guide plates (10 mm thick) and fuel basket tube thickness (5 mm) are included as a combined total thickness of 15 mm (CRWMS M&O 2000b, Attachment I).

Rationale: Inclusion of fuel basket materials in the smeared material composition would increase the overall density and, consequently, increase the attenuation of the radiation. Therefore, this assumption is conservative. No further confirmation of this assumption is required.

Usage: This assumption is used in Section 5.6.2.2.

- 3.4** For the point-kernel integration approximation with the PATH code, iron (Fe) is assumed to simulate the following materials: Inconel-718, A516 carbon steel, SS316L stainless steel and Alloy 22. In addition, the chemical element, Mo is assumed to represent Zr-4 in the fuel region.

Rationale: PATH performs gamma calculations only. Gamma attenuation through a medium is mainly affected by the material density (g/cm^3), and its mass attenuation coefficients (cm^2/g). PATH calculations use the actual density for each material. However, the mass attenuation coefficients for iron are used for Inconel-718, A516 carbon

steel, SS316L stainless steel and Alloy 22, as the attenuation coefficients are fairly insensitive to elements with similar or close atomic numbers (ANSI/ANS-6.4.3-1991, p. 7). The same rationale applies to replacement of Zr-4 with Mo (ANSI/ANS-6.4.3-1991, p. 7). These replacements are necessary to facilitate the calculation, because of the lack of the attenuation coefficients for certain elements in the data library. Since PATH is used in this calculation for scoping purposes only, no further confirmation of this assumption is required.

Usage: This assumption is used in Section 5.6.2.1.

- 3.5** For shielding modeling purposes, the waste package and its transporter are both centered in the main drift.

Rationale: This assumption simplifies the waste package and transporter model, and facilitates tallies of dose rate results on the surfaces for improved statistics in the Monte Carlo calculation. This assumption poses no significant effect on the shielding results. Therefore, no further confirmation of this assumption is required.

Usage: This assumption is used in Sections 5.6.2 and 5.7.

- 3.6** For MCNP calculations, the axial length of the shielding model is assumed to be infinite.

Rationale: The axial length of the source region (i.e., fuel assembly) is sufficiently long, relative to the distance from the source to the dose points of interest. Furthermore, an infinite model results in slightly higher dose rates than a finite model. Therefore, this assumption is conservative, and no further confirmation of this assumption is required.

Usage: This assumption is used in Section 5.7.

- 3.7** For dose rate calculations, all the fuel assemblies in the waste package are assumed to be of the same characteristics with identical source terms.

Rationale: This assumption simplifies the analytical model and enables homogenization of the fuel region. Because of the self-shielding effects by fuel assemblies, only the outer row of fuel assemblies in the fuel basket make significant contributions to the dose rates external to the waste package (demonstrated in Table 16). This assumption represents a common practice used in this type of shielding calculation. Therefore, no further confirmation of this assumption is required.

Usage: This assumption is used in Section 5.6.

- 3.8** The 1999 design basis waste input is used to obtain the waste stream parameters including commercial spent fuel assembly initial age and heat distribution (CRWMS M&O 1999a, pp. 2 and 15).

Rationale: The 1999 design basis waste input was developed for the Site Recommendation design. It represents the best information currently available. The 2002 design basis waste input as discussed in Section 5.3 is still under development. This change will mainly impact the surface facility design and waste aging requirements. For the subsurface design, the source term specification based on 1999 design basis waste input may remain valid, provided that the thermal output per waste package is limited to 11.8 kW (see Section 5.4) and the fuel aging option remains available on the surface. The thermal output per waste package based on the shielding source term is substantially above the limit of 11.8 kW (see Section 5.5.2). Therefore, no further confirmation of this assumption is required, based on the current design.

Usage: This assumption is used in Section 5.3.

- 3.9 This calculation uses the document on *PWR Source Term Generation and Evaluation* (CRWMS M&O 1999d) for a typical B&W Mark B PWR fuel assembly to obtain the neutron and gamma sources for determination of dose rates.

Rationale: The cited document provides the PWR spent fuel assembly source terms for the various enrichments, burnups and cooling times (CRWMS M&O 1999d, Table 18 and Attachment IV). It represents the best information currently available, and is used consistently throughout the project. These source terms are based on a slightly conservative uranium loading of 0.475 MTU (CRWMS M&O 1999d, p. 7) rather than the actual loading of 0.464 MTU (CRWMS M&O 1999d, p. 10). The source terms are used in this calculation to evaluate impact on the waste package and its transporter surface dose rates. The fuel parameters required for the source term specification are not affected. Therefore, no further confirmation of this assumption is required.

Usage: This assumption is used in Sections 5.5.2 and 5.6.1.

- 3.10 The waste package transporter neutron shielding material is assumed to be boron-polyethylene with a density of 0.95 g/cm³, containing 61.2% carbon, 22.2% oxygen, 11.6% hydrogen and 5% boron by weight (Reactor Experiments 1991).

Rationale: Boron-polyethylene or its equivalent is the typical neutron shielding material used for spent fuel transportation casks. The chemical composition for this material is the vendor-supplied information, and represents the best information available. The density is similar to that for unborated polyethylene. The addition of a nominal amount of boron is for minimizing secondary gamma production from neutron interactions. A different neutron shielding material may be used for the waste package transporter. However, the overall transporter shielding mass is insensitive to the change in the neutron shielding material (CRWMS M&O 1998a, p. 39). Therefore, no further confirmation of this assumption is required.

Usage: This assumption is used in Table 11.

4. USE OF COMPUTER SOFTWARE

4.1 BASELINE SOFTWARE

The following qualified baseline software items were obtained from Software Configuration Management in accordance with appropriate procedures. These items were appropriate for use in this calculation, according to the applications and capabilities of these codes. They were used within the range of validation. The input and output files are listed in Attachment I, and stored in ASCII format on an electronic medium (compact disk) in accordance with AP-13Q.

4.1.1 MCNP

The MCNP code as identified below was used to calculate both neutron and gamma dose rates on the WP surface and transporter surface.

Program name: MCNP (CRWMS M&O 1998b)
Version/revision number: Version 4B2LV
CSCI number: 30033-4B2LV-
Computer type: Dell Desktop Pentium PC (CPU #112111)
Operating system: Windows 95, Version 4.00.1111

4.1.2 PATH

The PATH code as identified below was used to calculate the gamma dose rates only on the WP surface and transporter surface.

Program name: PATH (CRWMS M&O 1996a)
Version/revision number: Version 88A
CSCI number: 30007-88A-
Computer type: Dell Desktop Pentium PC (CPU #112111)
Operating system: Windows 95, Version 4.00.1111 with the MS-DOS capability

4.2 SOFTWARE ROUTINES

The following Excel spreadsheet program was used to perform simple arithmetic calculations, as indicated in Section 6.2.1 of this document. The user-defined formulas, inputs, and results are documented in sufficient detail to allow independent repetition of the various calculations.

Title: Excel
Version/revision number: Microsoft Excel 97

5. CALCULATION

5.1 REVIEW AND COMPILATION OF SOURCE TERMS

This section reviews, compiles and discusses the source terms generated for YMP for the various waste forms. The focus here is on the source terms for shielding-specific applications.

5.1.1 PWR SNF

The source terms for PWR SNF are provided in *PWR Source Term Generation and Evaluation* (CRWMS M&O 1999d) for the various combinations of initial enrichment, burnup and cooling time. Of particular interest to shielding applications are the source terms for the maximum and average PWR fuel assemblies, respectively, as specified below:

Maximum PWR assembly: 5.0%, 75 GWd/MTU and 5 years old
(CRWMS M&O 1999d, p.24)

Average PWR assembly: 4.0%, 48 GWd/MTU and 25 years old
(CRWMS M&O 1999d, p. 24)

The corresponding heat generation rates are given below:

Maximum PWR assembly: 2.266 kW/assembly
(CRWMS M&O 1999d, Attachment IV)

Average PWR assembly: 0.601 kW/assembly
(CRWMS M&O 1999d, Attachment IV)

Table 1 lists the neutron source terms by energy group for the maximum and average PWR fuel assembly, obtained from CRWMS M&O 1999d. Table 2 provides the same type of information for the gamma source terms. Note that the neutron source terms are in the fuel region only, and the gamma source terms include the four different regions of the fuel assembly: fuel, bottom, plenum and top.

Note that the maximum and average fuel assemblies described in this section represent the specifications defined in CRWMS M&O 1999d for use in waste package radiation analysis. These assemblies may not correspond to the expected maximum and average fuel assemblies based on the projected waste stream scenarios (see Section 5.5.1). Furthermore, the specification of the maximum and average fuel assemblies is subject to change, depending on the waste stream scenarios.

Table 1. Maximum and Average PWR SNF Neutron Source Terms

Neutron Energy Range (MeV)		Neutron Source (n/s per assembly)	
Upper Bound	Lower Bound	Maximum ^a	Average ^b
2.00E+01	6.43E+00	3.06E+07	3.65E+06
6.43E+00	3.00E+00	3.45E+08	4.18E+07
3.00E+00	1.85E+00	3.78E+08	4.69E+07
1.85E+00	1.40E+00	2.15E+08	2.61E+07
1.40E+00	9.00E-01	2.92E+08	3.52E+07
9.00E-01	4.00E-01	3.19E+08	3.82E+07
4.00E-01	1.00E-01	6.25E+07	7.48E+06
1.00E-01	1.70E-02	0.00E+00	0.00E+00
1.70E-02	3.00E-03	0.00E+00	0.00E+00
3.00E-03	5.50E-04	0.00E+00	0.00E+00
5.50E-04	1.00E-04	0.00E+00	0.00E+00
1.00E-04	3.00E-05	0.00E+00	0.00E+00
3.00E-05	1.00E-05	0.00E+00	0.00E+00
1.00E-05	3.05E-06	0.00E+00	0.00E+00
3.05E-06	1.77E-06	0.00E+00	0.00E+00
1.77E-06	1.30E-06	0.00E+00	0.00E+00
1.30E-06	1.13E-06	0.00E+00	0.00E+00
1.13E-06	1.00E-06	0.00E+00	0.00E+00
1.00E-06	8.00E-07	0.00E+00	0.00E+00
8.00E-07	4.00E-07	0.00E+00	0.00E+00
4.00E-07	3.25E-07	0.00E+00	0.00E+00
3.25E-07	2.25E-07	0.00E+00	0.00E+00
2.25E-07	1.00E-07	0.00E+00	0.00E+00
1.00E-07	5.00E-08	0.00E+00	0.00E+00
5.00E-08	3.00E-08	0.00E+00	0.00E+00
3.00E-08	1.00E-08	0.00E+00	0.00E+00
1.00E-08	1.00E-11	0.00E+00	0.00E+00

^a Source: CRWMS M&O 1999d, Attachment IV, File *PWR.neutron.source* for PWR fuel with 5% enrichment, 75 GWd/MTU burnup and 5 yr cooling.

^b Source: CRWMS M&O 1999d, Attachment IV, File *PWR.neutron.source* for PWR fuel with 4% enrichment, 48 GWd/MTU burnup and 25 yr cooling.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

Table 2. Maximum and Average PWR SNF Gamma Source Terms

Gamma Energy Range (MeV)		Maximum Source (γ 's/s per assembly) ^a				Average Source (γ 's/s per assembly) ^b			
		Fuel	Bottom	Plenum	Top	Fuel	Bottom	Plenum	Top
5.00E-02	1.00E-02	2.23E+15	5.60E+11	5.01E+11	3.58E+11	6.70E+14	3.36E+10	1.86E+10	2.17E+10
1.00E-01	5.00E-02	6.20E+14	1.09E+11	5.76E+10	7.01E+10	1.99E+14	6.02E+09	3.14E+09	3.87E+09
2.00E-01	1.00E-01	5.03E+14	2.67E+10	3.35E+10	1.69E+10	1.26E+14	1.46E+09	8.53E+08	9.36E+08
3.00E-01	2.00E-01	1.43E+14	1.33E+09	1.86E+09	8.41E+08	3.89E+13	7.30E+07	4.39E+07	4.69E+07
4.00E-01	3.00E-01	9.52E+13	1.79E+09	5.58E+09	1.10E+09	2.63E+13	9.47E+07	7.16E+07	6.07E+07
6.00E-01	4.00E-01	1.42E+15	1.82E+09	1.05E+11	6.99E+07	2.05E+13	1.41E+07	5.04E+08	3.83E+06
8.00E-01	6.00E-01	4.40E+15	4.07E+09	5.67E+10	2.20E+09	1.24E+15	2.08E+09	1.92E+09	1.44E+09
1.00E+00	8.00E-01	6.53E+14	1.33E+11	7.67E+09	7.44E+10	1.10E+13	2.08E+09	1.64E+09	1.44E+09
1.33E+00	1.00E+00	4.29E+14	3.19E+13	1.64E+13	2.05E+13	2.95E+13	1.75E+12	9.09E+11	1.12E+12
1.66E+00	1.33E+00	1.22E+14	9.00E+12	4.64E+12	5.78E+12	5.13E+12	4.94E+11	2.57E+11	3.18E+11
2.00E+00	1.66E+00	1.39E+12	1.85E+03	8.72E+02	1.13E+03	6.75E+10	9.73E-01	6.14E+01	8.72E-03
2.50E+00	2.00E+00	2.48E+12	2.14E+08	1.10E+08	1.37E+08	3.53E+09	1.17E+07	6.09E+06	7.54E+06
3.00E+00	2.50E+00	1.05E+11	3.31E+05	1.71E+05	2.13E+05	2.88E+08	1.82E+04	9.44E+03	1.17E+04
4.00E+00	3.00E+00	1.32E+10	5.35E-08	7.00E-09	2.91E-08	1.98E+07	1.86E-11	1.49E-11	1.27E-11
5.00E+00	4.00E+00	5.54E+07	0.00E+00	0.00E+00	0.00E+00	6.69E+06	0.00E+00	0.00E+00	0.00E+00
6.50E+00	5.00E+00	2.22E+07	0.00E+00	0.00E+00	0.00E+00	2.69E+06	0.00E+00	0.00E+00	0.00E+00
8.00E+00	6.50E+00	4.36E+06	0.00E+00	0.00E+00	0.00E+00	5.27E+05	0.00E+00	0.00E+00	0.00E+00
1.00E+01	8.00E+00	9.26E+05	0.00E+00	0.00E+00	0.00E+00	1.12E+05	0.00E+00	0.00E+00	0.00E+00

^a Source: CRWMS M&O 1999d, Attachment IV, File *PWR.gamma.source* for PWR fuel with 5% enrichment, 75 GWd/MTU burnup and 5 yr cooling.

^b Source: CRWMS M&O 1999d, Attachment IV, File *PWR.gamma.source* for PWR fuel with 4% enrichment, 48 GWd/MTU burnup and 25 yr cooling.

5.1.2 BWR SNF

The source terms for BWR SNF are provided in *BWR Source Term Generation and Evaluation* (CRWMS M&O 1999b) for the various combinations of initial enrichment, burnup and cooling time. Of particular interest to shielding applications are the source terms for the maximum and average BWR fuel assemblies, respectively, as specified below:

Maximum BWR assembly: 5.0%, 75 GWd/MTU and 5 years old
(CRWMS M&O 1999b, p.46)

Average BWR assembly: 3.5%, 40 GWd/MTU and 25 years old
(CRWMS M&O 1999b, p.46)

The corresponding heat generation rates are given below:

Maximum BWR assembly: 0.78 kW/assembly
(CRWMS M&O 1999b, Attachment VII)

Average BWR assembly: 0.19 kW/assembly
(CRWMS M&O 1999b, Attachment VII)

Table 3 lists the neutron source terms by energy group for the maximum and average BWR fuel assembly, obtained from CRWMS M&O 1999b (Table 51 and Attachment V11, p. 57). Table 4 provides the same type of information for the gamma source terms. Note that the neutron source terms are in the fuel region only, and the gamma source terms include the four different regions of the fuel assembly: fuel, bottom, plenum and top.

Table 3. Maximum and Average BWR SNF Neutron Source Terms

Neutron Energy Range (MeV)		Neutron Source (n/s per assembly)	
Upper Bound	Lower Bound	Maximum ^a	Average ^b
2.00E+01	6.43E+00	1.07E+07	6.88E+05
6.43E+00	3.00E+00	1.21E+08	7.95E+06
3.00E+00	1.85E+00	1.32E+08	9.02E+06
1.85E+00	1.40E+00	7.53E+07	4.97E+06
1.40E+00	9.00E-01	1.02E+08	6.65E+06
9.00E-01	4.00E-01	1.12E+08	7.21E+06
4.00E-01	1.00E-01	2.19E+07	1.41E+06
1.00E-01	1.70E-02	0.00E+00	0.00E+00
1.70E-02	3.00E-03	0.00E+00	0.00E+00
3.00E-03	5.50E-04	0.00E+00	0.00E+00
5.50E-04	1.00E-04	0.00E+00	0.00E+00
1.00E-04	3.00E-05	0.00E+00	0.00E+00
3.00E-05	1.00E-05	0.00E+00	0.00E+00
1.00E-05	3.05E-06	0.00E+00	0.00E+00
3.05E-06	1.77E-06	0.00E+00	0.00E+00
1.77E-06	1.30E-06	0.00E+00	0.00E+00
1.30E-06	1.13E-06	0.00E+00	0.00E+00
1.13E-06	1.00E-06	0.00E+00	0.00E+00
1.00E-06	8.00E-07	0.00E+00	0.00E+00
8.00E-07	4.00E-07	0.00E+00	0.00E+00
4.00E-07	3.25E-07	0.00E+00	0.00E+00
3.25E-07	2.25E-07	0.00E+00	0.00E+00
2.25E-07	1.00E-07	0.00E+00	0.00E+00
1.00E-07	5.00E-08	0.00E+00	0.00E+00
5.00E-08	3.00E-08	0.00E+00	0.00E+00
3.00E-08	1.00E-08	0.00E+00	0.00E+00
1.00E-08	1.00E-11	0.00E+00	0.00E+00

^a Source: CRWMS M&O 1999b, Attachment VII, File *BWR.neutron.source* for BWR fuel with 5% enrichment, 75 GWd/MTU burnup and 5 yr cooling.

^b Source: CRWMS M&O 1999b, Attachment VII, File *BWR.neutron.source* for BWR fuel with 3.5% enrichment, 40 GWd/MTU burnup and 25 yr cooling.

Originator: sc Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

Table 4. Maximum and Average BWR SNF Gamma Source Terms

Gamma Energy Range (MeV)		Maximum Source (γ/s per assembly) ^a				Average Source (γ/s per assembly) ^b			
		Fuel	Bottom	Plenum	Top	Fuel	Bottom	Plenum	Top
5.00E-02	1.00E-02	8.01E+14	3.63E+11	7.92E+11	3.80E+11	2.30E+14	3.32E+10	5.26E+10	3.41E+10
1.00E-01	5.00E-02	2.21E+14	8.51E+10	1.55E+11	8.86E+10	6.79E+13	4.02E+09	7.64E+09	4.21E+09
2.00E-01	1.00E-01	1.73E+14	1.44E+11	1.68E+11	1.45E+11	4.33E+13	2.20E+10	2.29E+10	2.20E+10
3.00E-01	2.00E-01	4.96E+13	2.37E+10	2.49E+10	2.37E+10	1.34E+13	4.24E+09	4.28E+09	4.24E+09
4.00E-01	3.00E-01	3.31E+13	2.22E+09	5.05E+09	2.27E+09	9.21E+12	3.44E+08	4.09E+08	3.47E+08
6.00E-01	4.00E-01	4.38E+14	3.06E+10	6.93E+10	3.06E+10	6.92E+12	4.95E+09	5.13E+09	4.95E+09
8.00E-01	6.00E-01	1.60E+15	9.41E+10	1.15E+11	9.41E+10	4.16E+14	1.67E+10	1.72E+10	1.68E+10
1.00E+00	8.00E-01	2.03E+14	1.28E+11	1.06E+11	1.06E+11	3.15E+12	1.76E+10	1.80E+10	1.77E+10
1.33E+00	1.00E+00	6.77E+13	4.32E+12	2.47E+13	5.34E+12	4.91E+12	2.42E+11	1.30E+12	2.97E+11
1.66E+00	1.33E+00	1.94E+13	1.18E+12	6.93E+12	1.47E+12	5.40E+11	6.09E+10	3.58E+11	7.66E+10
2.00E+00	1.66E+00	3.77E+11	1.48E+07	1.48E+07	1.48E+07	2.36E+10	2.69E+06	2.69E+06	2.69E+06
2.50E+00	2.00E+00	5.99E+11	2.78E+07	1.64E+08	3.47E+07	1.20E+09	1.41E+06	8.47E+06	1.78E+06
3.00E+00	2.50E+00	2.72E+10	4.31E+04	2.55E+05	5.37E+04	6.44E+07	2.19E+03	1.31E+04	2.76E+03
4.00E+00	3.00E+00	3.43E+09	1.47E-10	3.07E-10	1.74E-10	3.75E+06	2.00E-10	2.25E-10	2.04E-10
5.00E+00	4.00E+00	1.95E+07	3.71E-11	3.70E-11	3.70E-11	1.27E+06	5.06E-11	5.06E-11	5.06E-11
6.50E+00	5.00E+00	7.81E+06	1.07E-11	1.07E-11	1.07E-11	5.07E+05	1.46E-11	1.46E-11	1.46E-11
8.00E+00	6.50E+00	1.53E+06	1.36E-12	1.36E-12	1.36E-12	9.95E+04	1.85E-12	1.85E-12	1.85E-12
1.00E+01	8.00E+00	3.25E+05	1.81E-13	1.81E-13	1.81E-13	2.11E+04	2.47E-13	2.47E-13	2.47E-13

^a Source: CRWMS M&O 1999b, Attachment VII, File *BWR.gamma.source* for BWR fuel with 5% enrichment, 75 GWd/MTU burnup and 5 yr cooling.

^b Source: CRWMS M&O 1999b, Attachment VII, File *BWR.gamma.source* for BWR fuel with 3.5% enrichment, 40 GWd/MTU burnup and 25 yr cooling.

5.1.3 DHLW

The source terms from DHLW canisters are documented in CRWMS M&O 2000f, including those representative of each of four facilities: Savannah River Plant (SRP), Hanford, Idaho Engineering and Environmental Laboratory, and West Valley Project. Comparison of these source terms for different DHLW canisters indicates that the canister from the SRP represents the worst-case for shielding considerations. The SRP canister has been selected as a basis in the dose rate calculations for the DHLW and DOE SNF co-disposal waste package (BSC 2001d).

Consistent with the basis used in BSC 2001d, Table 5 provides the neutron and gamma sources (CRWMS M&O 2000f, pp. VI-1 and V-1, respectively) for the SRP DHLW canister at year 2010.1.

5.1.4 DOE SNF

There is a wide variety of DOE SNF such as Fast Flux Test Facility (FFTF) fuel, Fermi fuel, TRIGA (Training, Research, Isotopes, General Atomic) fuel, etc. The DOE SNF in disposable canisters will be placed in the DHLW disposal container along with five DHLW glass canisters (CRWMS M&O 2000c). The waste package cavity allows an optimal emplacement of five DHLW glass canisters surrounding a DOE standardized SNF canister. Therefore, the support tube and DHLW glass canisters provide shielding for the DOE SNF canister, reducing significantly the dose rate contribution from the DOE SNF canister. The calculations of dose rates at the external surfaces of the DHLW/DOE SNF co-disposal waste packages have demonstrated that the bounding source terms for the DOE SNF arises from the Melt-Dilute Al SNF (CRWMS M&O 2000c, and BSC 2001d). The neutron and gamma source terms for the Melt-Dilute Al SNF are available in BSC 2001d (pp. 17 and I-2). Although the source terms of the Melt-Dilute Al SNF are comparable to those of the commercial SNF, the maximum dose rate at the external surfaces of the DHLW/DOE SNF co-disposal waste package is about five times lower than that of the 21-PWR waste package, as discussed in Section 5.2.

5.1.5 Naval SNF

Unlike other waste forms such as commercial and DOE SNF, the source terms for naval SNF are unavailable in units of neutrons and photons per second in the fuel region. Instead, *Thermal, Shielding, and Structural Information on the Naval Spent Nuclear Fuel (SNF) Canister* (Naples 1999, Enclosure 2, p. 2) provides the neutron and photon currents on various surfaces of the naval SNF canister at 2 years decay.

Since the minimum cooling time required for standard SNF is 5 years per 10CFR961.11 (Appendix E), CRWMS M&O 2000a (Attachment II, p. II-2) adjusted the photon currents by the group-dependent decay factors provided in Naples 1999, Enclosure 2 (p.7) to reflect the decay time of 5 years. However, no adjustment was made to the neutron current, as the neutron contribution is relatively insignificant in comparison to the photon current. Table 6 reproduces the source terms used in CRWMS M&O 2000a for dose rate calculations.

Table 5. Neutron and Gamma Sources per SRP DHLW Glass Canister at Year 2010.1

Neutron Source ^a			Gamma Source ^b		
Energy Range (MeV)		n /s per canister	Energy Range (MeV)		γ/s per canister
2.00E+01	6.43E+00	2.99E+05	5.00E-02	1.00E-02	1.29E+15
6.43E+00	3.00E+00	2.74E+07	1.00E-01	5.00E-02	3.89E+14
3.00E+00	1.85E+00	2.12E+07	2.00E-01	1.00E-01	3.02E+14
1.85E+00	1.40E+00	5.21E+06	3.00E-01	2.00E-01	8.58E+13
1.40E+00	9.00E-01	5.98E+06	4.00E-01	3.00E-01	6.27E+13
9.00E-01	4.00E-01	5.58E+06	6.00E-01	4.00E-01	8.55E+13
4.00E-01	1.00E-01	1.60E+06	8.00E-01	6.00E-01	1.34E+15
1.00E-01	1.70E-02	1.54E+05	1.00E+00	8.00E-01	2.08E+13
1.70E-02	3.00E-03	0.00E+00	1.33E+00	1.00E+00	2.91E+13
3.00E-03	5.50E-04	0.00E+00	1.66E+00	1.33E+00	6.18E+12
5.50E-04	1.00E-04	0.00E+00	2.00E+00	1.66E+00	4.86E+11
1.00E-04	3.00E-05	0.00E+00	2.50E+00	2.00E+00	2.70E+12
3.00E-05	1.00E-05	0.00E+00	3.00E+00	2.50E+00	1.91E+10
1.00E-05	3.05E-06	0.00E+00	4.00E+00	3.00E+00	2.15E+09
3.05E-06	1.77E-06	0.00E+00	5.00E+00	4.00E+00	5.20E+05
1.77E-06	1.30E-06	0.00E+00	6.50E+00	5.00E+00	2.09E+05
1.30E-06	1.13E-06	0.00E+00	8.00E+00	6.50E+00	4.09E+04
1.13E-06	1.00E-06	0.00E+00	1.00E+01	8.00E+00	8.67E+03
1.00E-06	8.00E-07	0.00E+00			
8.00E-07	4.00E-07	0.00E+00			
4.00E-07	3.25E-07	0.00E+00			
3.25E-07	2.25E-07	0.00E+00			
2.25E-07	1.00E-07	0.00E+00			
1.00E-07	5.00E-08	0.00E+00			
5.00E-08	3.00E-08	0.00E+00			
3.00E-08	1.00E-08	0.00E+00			
1.00E-08	1.00E-11	0.00E+00			
Total		6.74E+07			3.61E+15

^a Source: CRWMS M&O 2000f, Attachment VI, p. VI-1 for the neutron source.

^b Source: CRWMS M&O 2000f, Attachment V, p. V-1 for the gamma source.

Table 6. Neutron and Gamma Current Sources Exiting Naval Spent Fuel Canister Side Surface

Neutron Current ^a		Gamma Current ^b	
Upper Energy (MeV)	2-yr Decay (n/cm ² -s)	Upper Energy (MeV)	5-yr Decay (γ/cm ² -s)
2.117E+01	3.644E-02	4.000E-01	9.928E+06
1.284E+01	2.242E-01	9.000E-01	8.120E+09
1.000E+01	9.292E-01	1.350E+00	6.486E+07
7.790E+00	2.600E+00	1.800E+00	7.720E+07
6.070E+00	5.663E+00	2.200E+00	7.403E+06
4.720E+00	2.475E+01	2.600E+00	1.091E+05
2.860E+00	5.713E+01	3.000E+00	1.269E+04
1.740E+00	1.937E+02	4.000E+00	3.490E+02
8.210E-01	2.875E+02	5.000E+00	5.492E+00
3.897E-01	2.426E+02	6.000E+00	4.631E-08
1.830E-01	1.479E+02	1.000E+01	2.296E-03
6.740E-02	9.030E+01		
5.530E-03	2.405E+01		
2.260E-05	2.327E+00		
6.250E-07	2.357E-02		
Total	1.080E+03	Total	8.280E+09

^a Source: Naples 1999, Enclosure 2, p. 4 at 2 yr after reactor shutdown. For conservatism, no correction to 5 yr was made, because of a small neutron contribution relative to gamma.

^b Source: CRWMS M&O 2000a, Attachment II, p II-2 at 5 yr after reactor shutdown, corrected from Naples 1999, Enclosure 2, p. 4 at 2 yr after reactor shutdown.

5.2 REVIEW OF WASTE PACKAGE DOSE RATE CALCULATIONS

Several dose rate calculations have been performed for the different waste package types including the following:

- 21-PWR Uncanistered Fuel (UCF) Waste Package
- 44-BWR UCF Waste Package
- DHLW/DOE SNF Co-disposal Waste Package
- Single-Corrosion-Resistant-Material (CRM) Naval SNF Waste Package

Other WP types such as the 12-PWR and 24-BWR small waste packages are less radiation limiting than the corresponding large WPs, and thus pose no impact to determination of the limiting waste package. It has been demonstrated for the viability assessment (VA) WP design that with the same radiation source term, the resulting dose rate is less from the 12-PWR WP than from the 21-PWR WP (CRWMS M&O 1999e, p. 23 & Att. I-57, and p. 25 & Att. I-25).

Table 7 lists the maximum dose rate on the WP surface for each WP type considered, based on the bounding source terms. Table 7 also includes the average dose rates for the 21-PWR and 44-BWR waste packages for comparison. Comparison of the dose rates indicates that the 21-PWR waste package has the highest dose rate among the various WP types, and thus represents the limiting waste package for shielding considerations. Therefore, the 21-PWR waste package is selected here for specification of shielding-specific source terms.

5.3 WASTE STREAM AND FUEL ASSEMBLY HEAT DISTRIBUTION

1999 DESIGN BASIS WASTE INPUT

The projected waste stream for commercial PWR and BWR spent fuel to be received at the repository was developed in 1999 and described in CRWMS M&O 1999a. For this calculation, the focus is on PWR fuel only, which is more radiation limiting than BWR fuel, as discussed in Section 5.2.

The document cited above also provides the heat distribution for PWR fuel at arrival as reproduced in Table 8 and plotted in Figure 1. The distribution of fuel assemblies in each heat range depends on the waste receipt scenarios. The range of the percent of fuel assemblies for a given heat group in Column 2 of Table 8 covers the waste stream scenarios defined on p. 3 of CRWMS M&O 1999a for the likely scenarios of Cases A, B and C as follows:

Case A – Fuel selection begins with 10-year-old fuel and progresses to older fuel

Case B - Fuel selection begins with 10-year-old fuel and progresses to older fuel in strict order of fuel age

Case C - Fuel selection begins with oldest fuel still in pool and progresses to younger fuel

Table 7. WP Surface Dose Rate Comparison

Waste Package Type ^a	Dose Rate (rem/hr)		Reference
	Maximum	Average	
21-PWR Waste Package	1082.2	178.9	BSC 2001b, pp. 29 & 41
44-BWR Waste Package	940.2	119.6	BSC 2001c, pp. 25 & 37
DHLW/DOE SNF Co-disposal WP	193.5	N/A	BSC 2001d, p. 27
Naval SNF Waste Package	188.5	N/A	CRWMS M&O 2000a, p. 19

^a No dose rate calculations performed for the current 12-PWR and 24-BWR waste packages.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

Table 8. Summary Heat Distribution for PWR Fuel upon Receipt at Repository
 (1999 Design Basis Waste Input)

Heat Range (watts/assembly)	Range of Percent of Assemblies ^a	Average Percent	Average Cumulative Percent
0 - 99	0.9 - 1.0	0.95	0.95
100 - 199	7.0 - 8.3	7.65	8.60
200 - 299	13.9 - 17.9	15.90	24.50
300 - 399	13.9 - 16.3	15.10	39.60
400 - 499	8.8 - 13.8	11.30	50.90
500 - 599	7.9 - 13.4	10.65	61.55
600 - 699	7.6 - 14.4	11.00	72.55
700 - 799	8.3 - 9.4	8.85	81.40
800 - 999	8.1 - 14.3	11.20	92.60
1000 - 1199	2.3 - 6.5	4.40	97.00
1200 - 1399	0.9 - 2.0	1.45	98.45
1400 - 1599	0.5 - 0.6	0.55	99.00
1600 - 1799	0.2 - 0.3	0.25	99.25
1800 - 1999	0.1 - 0.1	0.10	99.35
MOX Fuel ^b	1.4 - 1.4	1.40	100.75 ^c

^a Source: CRWMS M&O 1999a, pp. 15 & 16.

^b Heat not calculated for mixed oxide (MOX) fuel.

^c Greater than 100%, owing to numerical averaging used.




Figure 1. Heat Distribution of PWR SNF Inventory upon Receipt at Repository
(1999 Design Basis Waste Input)

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

Column 3 of Table 8 provides the average percent of fuel assemblies in each heat group, which is simply the arithmetic mean of the corresponding range in Column 2. The heat distribution in Table 8 shows that 97 % of PWR fuel assemblies have heat generation rates at less than 1.2 kW/assembly. Although this coverage is based on the average of Cases A, B and C, the cumulative percent at 1.2 kW/assembly is practically similar among the three cases (CRWMS M&O 1999a, pp. 15 & 16). Therefore, use of ~1.2 kW/assembly as a basis for selection of the design basis fuel for subsurface shielding design will cover 97% of the historical and projected PWR SNF population (see discussion in Section 5.5), irrespective of the waste stream scenarios. The remaining 3% will require special considerations as discussed in Section 6.3.

2002 Design Basis Waste Input

The 2002 design basis waste input is currently under development. The waste stream scenarios being considered to cover possible utility fuel selection options range from a lower bound case to a limiting case as described below (BSC 2001a, pp. 11 & 12):

Oldest Fuel First (OFF) with No Dry Storage: a lower bound case that delivers the oldest CSNF in reactor pools to the repository first.

Youngest Fuel First Greater Than 10 Years Old (YFF10): a “middle of the road” scenario that delivers the youngest fuel first starting with 10-year-old fuel.

Youngest Fuel First Greater Than 5 Years Old in Strict Age Order (Strict YFF5): a hotter waste stream than YFF10 that delivers the youngest fuel first starting with 5-year-old fuel in strict age order without allocation exchange among nuclear power plants.

Limiting YFF5: a limiting selection scenario (unrealistic but bounding) that delivers the youngest fuel first starting with 5-year-old fuel in strict age order with allocation exchange among nuclear power plants.

Consideration of the strict or limiting YFF5 waste stream will change the fuel assembly heat distribution from the 1999 design basis waste input, and increase the source term, because the cooling time is 5 years rather than 10 years, and the younger (i.e. newer) fuel tends to have higher burnup. This change will mainly impact the surface facility design and waste aging requirements. For the subsurface facility design, the source term specification based on the 1999 design basis waste input may remain valid, provided that the thermal output per waste package is limited to 11.8 kW as discussed in Section 5.4 and the fuel aging option remains available on the surface. It is recommended that further impacts on the subsurface source term specification be assessed when the 2002 design basis waste input becomes available, including consideration of design options to accommodate the updated waste stream. For this calculation, the 1999 design basis waste input will be used as a basis for selection of the fuel assembly characteristics to determine the shielding source terms for the subsurface design (Assumption 3.8).

5.4 WASTE PACKAGE THERMAL SOURCE TERMS

The calculation document: *Waste Packages and Source Terms for the Commercial 1999 Design Basis Waste Streams* (CRWMS M&O 2000g) provides characterization of the heat generation rates of waste packages loaded with uncanistered commercial SNF assemblies. It contains the information on the fuel assembly contents and heat generation rate for each waste package at the time of emplacement in the repository. Loading of fuel assemblies in the waste packages is based on the waste stream scenarios described in CRWMS M&O 1999a, and a WP thermal output limit of 11.8 kW/WP (BSC 2001f, Section 1.2.4.2, p. 17). In addition to the WP heat generation rates, this calculation document also provides the maximum assembly heat generation rate as a function of year from the initial emplacement (i.e., 2010) to 2032 for the 63,000 MTU inventory case, and to 2040 for the 84,000 MTU commercial SNF inventory case.

For all fuel receipt scenarios, the maximum assembly heat generation rate is about 2.0 kW/assembly (CRWMS M&O 2000g, Table 17, File *preblend.dat*). For Cases A and B defined in Section 5.3, the typical maximum assembly heat generation rate is less than 1 kW/assembly until the later year of emplacement.

5.5 SELECTION OF DESIGN BASIS FUEL

5.5.1 SELECTION METHOD

The waste package specific source terms for shielding applications depend on the waste forms and waste package types. As shown in Section 5.2, the limiting waste package is the 21 PWR waste package. Hence, this waste package type is selected here for specification of the shielding source terms.

Consistent with the specification of contents required for the SNF transportation and storage casks (10CFR71.33 and 10CFR72.236, respectively), the waste package source term is specified by selecting a design basis fuel. Description of the design basis fuel needs to include the relevant fuel parameters such as fuel type, uranium loading, heat generation rate, initial enrichment, burnup and cooling time.

Selection of the design basis fuel requires the knowledge of the WP thermal output limit and maximum heat fuel assembly. For the 21 PWR waste package, the thermal output limit is 11.8 kW/WP as specified in Section 1.2.4.2 of BSC 2001f, corresponding to an average of 0.562 kW per fuel assembly (11.8 kW/21). The maximum heat fuel assembly is provided in Table 17, File *preblend.dat* of CRWMS M&O 2000g as ~2.0 kW per assembly, based on the projected waste stream scenarios. This maximum fuel assembly is 3.6 times the average fuel assembly (based on the 11.8 kW/WP limit for 21 PWR fuel assemblies) in terms of the thermal output. Use of the maximum fuel assembly as a design basis fuel would result in a total thermal output of ~42 kW/WP for the 21 PWR waste package, which is unduly conservative. On the other hand, it is inappropriate to use the average fuel assembly, because a small number of fuel assemblies in the waste package can dictate the shielding source terms and resulting dose rates.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

Because of the importance of a small number of fuel assemblies in the waste package for shielding considerations, the selected design basis fuel must provide sufficient coverage of the historical and projected SNF inventory to be received at the repository. For the VA design, a design basis fuel was used, bounding 97.85% of PWR SNF population (CRWMS M&O 1996b, p. 6) based on the oldest-fuel-first receipt scenario. To be comparable to the VA design, a similar coverage is selected in this calculation.

5.5.2 PWR DESIGN BASIS FUEL

The design basis fuel for the 21 PWR waste package is selected and justified below:

Fuel assembly class: Babcock & Wilcox (B&W) Mark B PWR fuel assemblies as used in *PWR Source Term Generation and Evaluation* (Assumption 3.9).

Initial mass of uranium per assembly for source terms: 0.475 MTU (CRWMS M&O 1999d, p. 7) (Assumption 3.9).

Cooling time: 10 years after reactor shutdown, corresponding to the initial fuel age for Cases A and B (CRWMS M&O 1999a, p. 3). See Section 6.3 for shorter cooling times.

Heat generation rate: ~1.2 kW/assembly, which is more than 2 times the average (Section 5.5.1), and covers 97% of PWR SNF population (Table 8), similar to the VA design. With 1.2 kW/assembly, the WP thermal output would be 25.2 kW, exceeding the limit of 11.8 kW. However, only a limited number of fuel assemblies in the waste package could contribute to the WP external dose rate. A waste package loaded with only a few assemblies with 1.2 kW/assembly while meeting the limit of 11.8 kW/WP could produce the same dose rate at the external surfaces of the waste package, as if the waste package were loaded with all 21 fuel assemblies containing 1.2 kW each. See Section 6.3 for loading of fuel assemblies with heat generation rates of more than 1.2 kW.

Initial fuel enrichment: 4%, which is the low end of the enrichment range for high burnup fuel based on the DOE Characteristics Data Base (DOE 1992, p. 2.4-3). A lower enrichment tends to produce a higher source term, as demonstrated in *PWR Source Term Generation and Evaluation* (CRWMS M&O 1999d), and indicated in *Standard Review Plan for Spent Fuel Dry Storage Facilities* (NRC 2000, p. 7-10).

Fuel burnup: 60 GWd/MTU, which is higher than the maximum burnup (58 GWd/MTU) for the historical PWR SNF inventory as of 1995 (CRWMS M&O 1999a, p. B-14). The burnup value of 60 GWd/MTU in conjunction with the cooling time of 10 years and initial enrichment of 4% results in a heat generation rate of approximately 1.2 kW/assembly (CRWMS M&O 1999d, Attachment IV). See Section 6.3 for fuel assemblies with burnup in excess of 60 GWd/MTU expected in the projected inventory.

Tables 9 and 10 provide the neutron and gamma source terms for the selected design basis fuel specification. Uniform fuel burnup within the fuel assembly is assumed (Assumption 3.2). These source terms are used in all subsequent dose rate calculations for this evaluation.

Table 9. Design Basis PWR SNF Neutron Source Terms

Neutron Energy Range (MeV)		Neutron Source (n/s per assembly)
Upper Bound	Lower Bound	Design Basis ^a
2.00E+01	6.43E+00	1.54E+07
6.43E+00	3.00E+00	1.74E+08
3.00E+00	1.85E+00	1.91E+08
1.85E+00	1.40E+00	1.09E+08
1.40E+00	9.00E-01	1.48E+08
9.00E-01	4.00E-01	1.61E+08
4.00E-01	1.00E-01	3.16E+07
1.00E-01	1.70E-02	0.00E+00
1.70E-02	3.00E-03	0.00E+00
3.00E-03	5.50E-04	0.00E+00
5.50E-04	1.00E-04	0.00E+00
1.00E-04	3.00E-05	0.00E+00
3.00E-05	1.00E-05	0.00E+00
1.00E-05	3.05E-06	0.00E+00
3.05E-06	1.77E-06	0.00E+00
1.77E-06	1.30E-06	0.00E+00
1.30E-06	1.13E-06	0.00E+00
1.13E-06	1.00E-06	0.00E+00
1.00E-06	8.00E-07	0.00E+00
8.00E-07	4.00E-07	0.00E+00
4.00E-07	3.25E-07	0.00E+00
3.25E-07	2.25E-07	0.00E+00
2.25E-07	1.00E-07	0.00E+00
1.00E-07	5.00E-08	0.00E+00
5.00E-08	3.00E-08	0.00E+00
3.00E-08	1.00E-08	0.00E+00
1.00E-08	1.00E-11	0.00E+00

^a Source: CRWMS M&O 1999d, Attachment IV, File *PWR.neutron.source* for PWR fuel with 4% enrichment, 60 GWd/MTU burnup and 10 yr cooling.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

Table 10. Design Basis PWR SNF Gamma Source Terms

Gamma Energy Range (MeV)		Gamma Source (γ 's/s per assembly) ^a			
		Fuel	Bottom	Plenum	Top
5.00E-02	1.00E-02	1.21E+15	2.73E+11	1.88E+11	1.75E+11
1.00E-01	5.00E-02	3.29E+14	5.28E+10	2.77E+10	3.39E+10
2.00E-01	1.00E-01	2.45E+14	1.28E+10	1.17E+10	8.19E+09
3.00E-01	2.00E-01	7.13E+13	6.39E+08	6.33E+08	4.07E+08
4.00E-01	3.00E-01	4.55E+13	8.50E+08	1.64E+09	5.33E+08
6.00E-01	4.00E-01	2.26E+14	4.92E+08	2.69E+10	3.37E+07
8.00E-01	6.00E-01	2.37E+15	2.91E+09	1.60E+10	1.86E+09
1.00E+00	8.00E-01	1.22E+14	5.40E+09	2.48E+09	3.41E+09
1.33E+00	1.00E+00	1.95E+14	1.54E+13	7.97E+12	9.90E+12
1.66E+00	1.33E+00	4.50E+13	4.35E+12	2.25E+12	2.80E+12
2.00E+00	1.66E+00	1.52E+11	2.35E+00	1.49E+02	2.15E-02
2.50E+00	2.00E+00	5.17E+10	1.03E+08	5.34E+07	6.64E+07
3.00E+00	2.50E+00	3.79E+09	1.60E+05	8.29E+04	1.03E+05
4.00E+00	3.00E+00	4.97E+08	9.43E-10	1.55E-10	5.19E-10
5.00E+00	4.00E+00	2.82E+07	0.00E+00	0.00E+00	0.00E+00
6.50E+00	5.00E+00	1.13E+07	0.00E+00	0.00E+00	0.00E+00
8.00E+00	6.50E+00	2.22E+06	0.00E+00	0.00E+00	0.00E+00
1.00E+01	8.00E+00	4.71E+05	0.00E+00	0.00E+00	0.00E+00

^a Source: CRWMS M&O 1999d, Attachment IV, File *PWR.gamma.source* for PWR fuel with 4% enrichment, 60 GWd/MTU burnup and 10 yr cooling.

Originator: SS Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

5.6 FUEL ASSEMBLIES CONTRIBUTING TO DOSE RATES

In the following shielding calculations, all the fuel assemblies in the waste package are assumed to be of the same characteristics with identical source term in order to simplify the analytical model (Assumption 3.7). This approach is appropriate, as the fuel assemblies provide self-shielding effects. Only the fuel assemblies close to the dose points of interest make contributions to the dose rates external to the waste package. This section provides a calculation to determine the contributing fuel assemblies to the WP external dose rates. The calculation covers the gamma contribution only, which is more significant than the neutron contribution, and controls the shielding mass of the WP transporter.

Since the radial dose rate is more sensitive to the self-shielding effects of the fuel assemblies, the calculation considers the radial configuration only.

5.6.1 Calculation Inputs

Fuel cavity cross section: square (CRWMS M&O 2000b, Attachment I)

Fuel cavity dimension: 22.64 cm (CRWMS M&O 2000b, Attachment I)

WP and fuel basket dimensions and materials: (CRWMS M&O 2000b, Attachment I)

Fuel type: B&W Mark B PWR fuel assembly (Assumption 3.9)

Mass in active fuel region (per assembly)

U: 463.63 kg (BSC 2001b, Table I-4)

O: 62.83 kg (BSC 2001b, Table I-4)

Zr-4: 115.12 kg (BSC 2001b, Table I-4)

Inconel-718: 4.90 kg (BSC 2001b, Table I-4)

Total: 646.48 kg

Design basis fuel neutron source term: See Table 9 (Assumption 3.9).

Design basis fuel gamma source term: See Table 10 (Assumption 3.9).

Material densities and compositions: See Table 11. Material data for the SNF and WP components are consistent with those used by the Waste Package Department. Fresh, unirradiated fuel is assumed (Assumption 3.1).

Flux-to-dose rate conversion factors for neutrons: ANSI/ANS-6.1.1-1977, p. 4.

Flux-to-dose rate conversion factors for photons: ANSI/ANS-6.1.1-1977, p. 5.

Table 11. Material Compositions of SNF, WP Components, and Shielding Materials

Region	Material	Density (g/cm ³)	Wt. % Used	Reference
Fuel	4% Enriched Uranium	18.9 (Reference only, not used)	U234: 0.0347 U235: 4.0 U236: 0.0184 U238: 95.9469	BSC 2001b, p. I-3
Fuel	Zircaloy-4	6.56 (Reference only, not used)	Sn: 1.45 Fe: 0.21 Cr: 0.115 O: 0.125 Zr: 98.1	BSC 2001b, p.14
Fuel	Inconel 718	8.19 (Reference only, not used)	Ni: 51.50 Cr: 19.00 Nb: 5.125 Ta: 0 Mo: 3.05 Ti: 0.90 Al: 0.50 Co: 1.00 C: 0.08 Mn: 0.35 Si: 0.35 P: 0.015 S: 0.015 B: 0.006 Cu: 0.30 Fe: 17.809	BSC 2001b, p. 14
WP Outer Barrier	Alloy C-22 (or Alloy 22)	8.69	Co: 2.5 Cr: 21.25 Mo: 13.5 W: 3.0 Fe: 4.0 Si: 0.08 Mn: 0.50 C: 0.015 V: 0.35 P: 0.02 S: 0.02 Ni: 54.765	BSC 2001b, p. 11
WP Inner Barrier & Transporter skin	SS316 (or SS316NG)	7.98	C: 0.08 Mn: 2.00 Si: 0.75 Cr: 17.00 Ni: 12.0 P: 0.045 S: 0.03 Mo: 2.5 N: 0.1 Fe: 65.495	BSC 2001b, p. 10
Transporter Gamma Shielding	A516 carbon steel	7.85	C: 0.27 Mn: 1.025 P: 0.035 S: 0.035 Si: 0.275 Fe: 98.36	BSC 2001b, p.10
Transporter Neutron Shielding	Boron-Polyethylene	0.95	C: 61.20 O: 22.20 H: 11.60 B: 5.00	Reactor Experiments 1991 (Assumption 3.10)
Main Drift Lining	Concrete (cured)	2.35	H: 0.55 O: 49.83 Si: 31.57 Ca: 8.26 Na: 1.70 Mg: 0.26 Al: 4.55 S: 0.13 K: 1.91 Fe: 1.23	ANSI/ANS-6.4-1997, Table 5.2, p. 9
Air Space	Dry Air	0.001204	N: 75.52 O: 23.18 C: 0.01 Ar: 1.29 note: these values are wt.% converted from volume %	Weast 1985, pp. F-10, F-156
Host Rock	Dry Tuff	2.21	Si: 36.801 Al: 6.441 Fe: 0.697 Ca: 0.339 Mg: 0.074 Ti: 0.061 Na: 3.027 K: 2.723 P: 0.009 Mn: 0.040 O: 49.815	CRWMS M&O 2000d, p. 12 CRWMS M&O 2000e, p. 32

5.6.2 PATH Calculation

The gamma dose rates external to the waste package were calculated with the PATH code (CRWMS M&O 1996a). This code is appropriate and suitable to quickly identify the important contributing fuel assemblies and to compare the results between different geometric models used. However, because of the approximations used in the code, PATH results lack the accuracy produced from other sophisticated shielding codes such as MCNP.

The PATH calculation considers two different geometric models; one with each individual fuel assembly explicitly modeled, and the other with all 21 fuel assemblies homogenized as a single region. This comparison serves to validate the model adopted for subsurface shielding applications. In both models, the waste package and transporter are both centered in the main drift (Assumption 3.5).

5.6.2.1 Explicit Fuel Assembly Model

For this model, each fuel assembly in the waste package is individually represented as shown in Figure 2. The fuel basket plates are included in the model, based on the dimensional and material inputs from CRWMS M&O 2000b (Attachment I). The waste package is contained in the transporter. The transporter model is identical to that used in *Evaluation of WP Transporter Neutron Shielding Materials* (CRWMS M&O 1998a, p. 30).

The contribution to the gamma dose rate from each fuel assembly is individually calculated with the PATH code at the selected dose points indicated in Figure 2 for identification of the peak position. The gamma source for each fuel assembly is represented by a volumetric source, obtained by dividing the gamma source strength in Table 9 for each energy group by the assembly cavity volume for the active fuel region. The respective cavity volume is given as:

$$(22.64 \text{ cm})^2 \times (360.172 \text{ cm}) = 1.846 \times 10^5 \text{ cm}^3$$

where 22.64 cm represents the side dimension of the square cavity, and 360.172 cm is the active fuel length (see Section 5.6.1). The materials in the fuel region are homogenized in a smeared region as shown in Table 12.

For simplicity in the PATH calculation, which is based on the point-kernel integration method, the following materials are simulated by iron: Inconel-718, A516 carbon steel, SS316L stainless steel, and Alloy 22, according to Assumption 3.4. This simulation is reasonable as iron with a similar atomic number is representative of the mass attenuation coefficients (cm^2/g) for these materials. Zr-4 in the fuel region is replaced by Mo, since PATH contains the attenuation data library for Mo, but not for Zr. The mass attenuation coefficients are similar for Mo and Zr (ANSI/ANS-6.4.3-1991, p.7).

Section 6.2.1 presents the results of the PATH calculation for the explicit individual fuel assembly model. The associated PATH input and output files are listed and described in Table 13. The fuel assemblies, which make negligible contributions to the dose rates at the points of interest, are omitted from the calculation and indicated in Table 13.




Figure 2. Explicit Fuel Assembly Model for PATH Calculation

Table 12. Smearred PWR Fuel Region

Material	Mass (kg) ^a	Mass Fraction ^b	Partial Density (g/cc) ^c
U	463.63	0.7172	2.512
O	62.83	0.0972	0.340
Zr-4 ^d	115.12	0.1780	0.624
Inconel-718 ^e	4.90	0.0076	0.026
Total	646.48	1.0	3.502

^a Mass inputs from Section 5.6.1.

^b Mass fraction = mass for a given material divided by 646.48 kg total.

^c Partial density = mass for a given material divided by the fuel cavity volume of $1.846 \times 10^5 \text{ cm}^3$

^d Simulated by Mo in PATH (Assumption 3.4).

^e Simulated by Fe in PATH (Assumption 3.4).

Table 13. PATH Input and Output Files for Explicit Fuel Assembly Model

Fuel ID ^a	Input File	Output File	Remark
A1	pwrwp05b.inp	pwrwp05b.out	For all dose points
A2	pwrwp08b.inp	pwrwp08b.out	For all dose points
A3	pwrwp10b.inp	pwrwp10b.out	For dose points @ 45° only
B1	pwrwp02b.inp	pwrwp02b.out	For all dose points
B2	pwrwp03b.inp	pwrwp03b.out	For all dose points
B3	pwrwp07b.inp	pwrwp07b.out	For all dose points
B4	Not calculated ^b		Negligible contribution ^b
B5	Not calculated		Negligible contribution
C1	pwrwp01b.inp	pwrwp01b.out	For all dose points
C2	pwrwp04b.inp	pwrwp04b.out	For all dose points
C3	pwrwp06b.inp	pwrwp06b.out	For all dose points
C4	Not calculated		Negligible contribution
C5	Not calculated		Negligible contribution
D1	pwrwp10b.inp	pwrwp10b.out	For all dose points
D2	pwrwp09b.inp	pwrwp09b.out	For all dose points
D3	pwrwp07b.inp	pwrwp07b.out	For dose points @ 0° only
D4	Not calculated		Negligible contribution
D5	Not calculated		Negligible contribution
E1	pwrwp05b.inp	pwrwp05b.out	For dose points @ 0° only
E2	pwrwp08b.inp	pwrwp08b.out	For dose points @ 0° only
E3	Not calculated		Negligible contribution

^a See Figure 2 for identification (ID) and location of each fuel assembly.

^b The contribution from this fuel assembly is not calculated, owing to substantial shielding by the front intervening fuel assemblies. This shielding effect results in a negligible contribution as estimated from the result for the immediately adjacent assembly. This footnote applies to all fuel assemblies marked with "Not Calculated".

5.6.2.2 Homogenized Model

The homogenized model for the fuel region is the same as the model used in *Shielding Calculation for Emplacement Operations and Subsurface Layout* (CRWMS M&O 2000e). All 21 fuel assemblies are homogenized as a single region with an equivalent radius of 58.53 cm (CRWMS M&O 2000e, p. 22). The model includes the thicknesses of the fuel basket corner guide and outer fuel assembly tube described as a ring around the homogenized fuel region. However, the model conservatively omits the internal fuel basket plates between the fuel assemblies (Assumption 3.3), ignoring the shielding effects of these plates.

With the homogenized model, there is no azimuthal or angular variation in the dose rate around the waste package or transporter. Hence, the dose rate is calculated only at a point on each of the following surfaces: WP outer surface, transporter inner surface, and transporter outer surface.

The results of the PATH calculation for the homogenized model are provided in Section 6.2.2. The associated input and output files are *PWRWP00.INP* and *PWRWP00.OUT*, respectively, as listed in Attachment I.

5.7 MCNP CALCULATION FOR HOMOGENIZED MODEL

The MCNP code is capable of treating detailed particle transport process for both neutrons and photons with accuracy. The MCNP code is used here to calculate both neutron and gamma dose rates. The calculation uses the homogenized fuel region model for comparison with the PATH calculation on the gamma contribution. The homogenized model is more conservative (i.e., higher dose rate results) for subsurface shielding applications than the explicit fuel assembly model, as demonstrated in the PATH calculation (Section 5.6) and its results (Section 6.2.1).

For the MCNP calculation, the model includes the main drift concrete lining and surrounding tuff medium to account for scattering effects from the drift wall as depicted in Figure 3, and uses Assumptions 3.5 and 3.6. Note that the PATH model in Figure 2 does not include the drift wall or tuff medium, as these regions are not in the path from the source to dose point for the point kernel integration.

The neutron and gamma source terms are from Tables 9 and 10, respectively. The neutron source input covers the full energy spectrum. However, only the contributing energy groups between 0.4 and 4.0 MeV are included in the gamma source input, consistent with the calculation in *Shielding Calculation for Emplacement Operations and Subsurface Layout* (CRWMS M&O 2000e, p. 10).

The material property inputs including densities and compositions are taken from Table 11. Table 14 lists the composition of smeared fuel for input into MCNP. Unlike the PATH calculations, the MCNP calculations use the actual material compositions for accurate representation.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering




Figure 3. Radial WP and Transporter Model for MCNP Calculation

Table 14. Fuel Region Smeared Composition for MCNP

Element	Mass per Fuel Assembly (g) ^a			Mass (g)	Weight Fraction
	Inconel - 718	Zircaloy - 4	UO ₂ (4% U-235)		
U - 238	0	0	4.4484E+05	4.4484E+05	6.881E-01
U - 235	0	0	1.8545E+04	1.8545E+04	2.869E-02
U - 236	0	0	8.5308E+01	8.5308E+01	1.320E-04
U - 234	0	0	1.6101E+02	1.6101E+02	2.491E-04
O	0	1.4390E+02	6.2828E+04	6.2972E+04	9.741E-02
Fe	8.7264E+02	2.4175E+02	0	1.1144E+03	1.724E-03
Cr	9.3100E+02	1.3239E+02	0	1.0634E+03	1.645E-03
Ni	2.5235E+03	0	0	2.5235E+03	3.903E-03
Nb	2.5113E+02	0	0	2.5113E+02	3.885E-04
Mo	1.4945E+02	0	0	1.4945E+02	2.312E-04
Ti	4.4100E+01	0	0	4.4100E+01	6.822E-05
Al	2.4500E+01	0	0	2.4500E+01	3.790E-05
Co	4.9000E+01	0	0	4.9000E+01	7.580E-05
C	3.9200E+00	0	0	3.9200E+00	6.064E-06
Mn	1.7150E+01	0	0	1.7150E+01	2.653E-05
Si	1.7150E+01	0	0	1.7150E+01	2.653E-05
P	7.3500E-01	0	0	7.3500E-01	1.137E-06
S	7.3500E-01	0	0	7.3500E-01	1.137E-06
B	2.9400E-01	0	0	2.9400E-01	4.548E-07
Cu	1.4700E+01	0	0	1.4700E+01	2.274E-05
Sn	0	1.6692E+03	0	1.6692E+03	2.582E-03
Zr	0	1.1293E+05	0	1.1293E+05	1.747E-01
Total	4.9000E+03	1.1512E+05	5.2646E+05	6.4648E+05	1

^a BSC 2001b (Table I-6, p. I-3). Elemental mass in each material obtained by multiplying the material mass (Section 5.6.1) by the weight percent (Table 11).

Originator: Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

The MCNP flux results are converted to dose rates in rem/hr, using the ANSI/ANS-6.1.1-1977 conversion factors. This unit is more appropriate for personnel shielding considerations than the unit of rad/hr used for radiation effects on materials.

As for the PATH homogenized model, the dose rates are calculated on the WP outer surface, transporter inner surface, and transporter outer surface. To obtain the contributions from all radiation source components, two MCNP runs were executed; one for the neutron and secondary gamma contributions, and the other for the fuel gamma contribution. The results of the MCNP calculations are presented in Section 6.2.3. The associated input and output files are as follows:

Neutron and secondary gamma: *wpneut0* (input) and *wpneut0.out* (output)
Fuel gamma: *wpgamma0* (input) and *wpgamma0.out* (output)

The MCNP input and output files are listed in Attachment I.

6. RESULTS AND RECOMMENDATIONS

This section presents the results of the calculation, and makes recommendations on the specification of the shielding source terms for use in the design of the waste emplacement and retrieval system and its associated facility. This specification is for Preliminary Design use only. The outputs of this calculation are all reasonable compared to the inputs selected. The results are suitable for the intended use. The source term specification covers 97% of the PWR fuel population rather than the bounding 100% coverage. Uncertainty associated with the remaining 3% will require special considerations as discussed in Section 6.3.

6.1 WP SPECIFIC SOURCE TERMS

The waste package specific source terms are provided and discussed in Section 5.5. The specification is for the limiting waste package, which is the 21 PWR waste package containing the selected design basis fuel. The characteristics of the design basis fuel are described in Section 5.5.2. The shielding source terms for this design basis fuel are provided in Table 9 for the neutron source and Table 10 for the gamma source. These source terms are recommended for use in the shielding analysis associated with the waste emplacement/retrieval system.

6.2 DOSE RATE RESULTS

6.2.1 PATH CALCULATION – EXPLICIT FUEL ASSEMBLY MODEL


Table 15 presents the results of the PATH calculation for the explicit fuel assembly model. The individual contributions are directly from the PATH outputs. Summation of the individual contributions is made with the Excel spreadsheet. The PATH calculation covers the gamma dose rates only. The results include the contribution from each fuel assembly for the design basis fuel specification with the characteristics of 4% initial enrichment, 60 GWd/MTU burnup and 10 years cooling. It needs to be pointed out that the PATH results are only approximate, because of the nature of the point-kernel integration method used in the PATH code.

The principal fuel assemblies contributing to the gamma dose rates are identified in Table 16 along with their percent contributions. Clearly, at every dose point, the closest three or four fuel assemblies contribute about 99% of the dose rate. The remaining fuel assemblies make little or no contributions, because of the shielding effects by the contributing assemblies. These results demonstrate that it takes only three or four fuel assemblies in the outer positions to produce the same dose rate as for the waste package containing 21 fuel assemblies with the same source term. Therefore, the dose rate outside the waste package is not dictated by the number of fuel assemblies contained in the waste package, but is rather affected by the characteristics of the fuel assemblies in the outer positions.

With the same source term for all fuel assemblies, the position of the peak dose rate depends on the surface location. On the waste package outer surface, the peak position occurs at the angle of 45° (see Table 15), because of the proximity of the contributing fuel assemblies to this dose point. As the dose point moves away from the WP surface, the peak position changes to the angle of 0° , as noted in Table 15 for the results on the inner and outer surfaces of the transporter.

Table 15. PATH Gamma Dose Rate Results for Explicit Fuel Assembly Model


Fuel ID	Gamma Dose Rate (rem/hr)								
	WP Outer Surface			Transporter Inner Surface			Transporter Outer Surface		
	0°	30°	45°	0°	30°	45°	0°	30°	45°
A1	3.611E-03	6.069E+01	1.772E+02	7.057E-01	5.820E+01	9.305E+01	1.199E-03	4.328E-02	7.535E-02
A2	3.342E-05	1.426E-01	1.799E-01	2.077E-04	9.479E-02	1.239E+00	1.222E-06	9.583E-05	2.269E-03
A3	nil	nil	6.982E-04	nil	nil	2.805E-02	nil	nil	8.073E-05
B1	9.709E+00	2.793E+02	1.772E+02	4.505E+01	1.200E+02	9.305E+01	3.885E-02	1.024E-01	7.535E-02
B2	6.410E-02	3.783E-01	3.783E+01	8.234E-02	3.767E+00	1.554E+01	1.661E-04	4.874E-03	1.504E-02
B3	2.810E-04	1.204E-03	6.575E-02	2.277E-04	2.693E-02	2.561E-02	6.979E-07	4.903E-05	3.469E-05
B4	nil	nil	nil	nil	nil	nil	nil	nil	nil
B5	nil	nil	nil	nil	nil	nil	nil	nil	nil
C1	3.527E+02	1.475E+00	1.799E-01	1.420E+02	9.943E+00	8.709E-01	1.170E-01	1.097E-02	1.386E-03
C2	5.733E-01	2.120E-02	6.575E-02	3.175E-01	2.421E-02	2.561E-02	5.057E-04	4.493E-05	3.469E-05
C3	2.412E-03	2.046E-04	5.982E-03	1.557E-03	1.339E-04	3.296E-03	2.778E-06	2.541E-07	5.608E-06
C4	nil	nil	nil	nil	nil	nil	nil	nil	nil
C5	nil	nil	nil	nil	nil	nil	nil	nil	nil
D1	9.709E+00	1.006E-02	6.982E-04	4.505E+01	1.049E+00	2.805E-02	3.885E-02	1.041E-03	8.073E-05
D2	6.410E-02	2.906E-04	2.561E-04	8.234E-02	1.806E-03	1.007E-04	1.661E-04	3.201E-06	1.835E-07
D3	2.810E-04	nil	nil	2.277E-04	nil	nil	6.979E-07	nil	nil
D4	nil	nil	nil	nil	nil	nil	nil	nil	nil
D5	nil	nil	nil	nil	nil	nil	nil	nil	nil
E1	3.611E-03	nil	nil	7.057E-01	nil	nil	1.199E-03	nil	nil
E2	3.342E-05	nil	nil	2.077E-04	nil	nil	1.222E-06	nil	nil
E3	nil	nil	nil	nil	nil	nil	nil	nil	nil
total	3.728E+02	3.420E+02	3.927E+02	2.340E+02	1.931E+02	2.039E+02	1.979E-01	1.628E-01	1.696E-01



Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

Table 16. Identification of Contributing Fuel Assemblies

Location	Dose Rate (rem/hr)	Fuel ID (% Contribution)				Subtotal
WP Outer Surface						
0°	372.8	B1 (2.60%)	C1 (94.61%)	D1 (2.60%)		99.81%
30°	342.0	A1 (17.75%)	B1 (81.67%)	C1 (0.43%)		99.85%
45°	392.7	A1 (45.12%)	B1 (45.12%)	B2 (9.63%)		99.87%
Transporter Inner Surface						
0°	234.0	B1 (19.25%)	C1 (60.68%)	D1 (19.25%)		99.18%
30°	193.1	A1 (30.14%)	B1 (62.14%)	B2 (1.95%)	C1 (5.15%)	99.38%
45°	203.9	A1 (45.64%)	A2 (0.61%)	B1 (45.64%)	B2 (7.62%)	99.51%
Transporter Outer Surface						
0°	0.198	B1 (19.63%)	C1 (59.12%)	D1 (19.63%)		98.38%
30°	0.163	A1 (26.58%)	B1 (62.90%)	B2 (3.00%)	C1 (6.74%)	99.22%
45°	0.170	A1 (44.43%)	A2 (1.34%)	B1 (44.43%)	B2 (8.87%)	99.07%



Originator: AZ Date: 12/09/02 Checker: GR Date: 12/09/02
 Nuclear Engineering

6.2.2 PATH CALCULATION – HOMOGENIZED MODEL

Using the same design basis fuel specification as for the explicit fuel assembly model, the PATH calculation for the homogenized model produces the following results of the gamma dose rates:

WP Outer Surface:	339.20 rem/hr
Transporter Inner Surface:	257.14 rem/hr
Transporter Outer Surface:	0.22 rem/hr

As compared with the results in Table 15 for the explicit fuel assembly model, the homogenized model produces higher results except on the WP outer surface. The lower dose rate on the WP outer surface with the homogenized model is due to the fact that the fuel assemblies are pushed inward for smearing purposes, increasing the distance from the source to the WP surface. The effect of this distance increase becomes less and less significant, as the dose point moves farther and farther away from the source.

For subsurface shielding applications, the interest is typically in the dose locations away from the waste package. The PATH results indicate that the homogenized model is conservative to use for subsurface shielding design, since it produces higher dose rates than the explicit fuel assembly modes at the points of interest to subsurface shielding considerations.

6.2.3 MCNP CALCULATION – HOMOGENIZED MODEL

Table 17 presents the MCNP results for the homogenized model, which is verified in the PATH calculation to be conservative and appropriate to use. The MCNP calculation includes the contributions from all pertinent radiation components: fuel gammas, fuel neutrons, and secondary gammas.

In comparison with the PATH gamma results for the homogenized model (see Table 18), there is no clear trend as to the corresponding MCNP results being higher or lower. On the WP outer surface and transporter surface, the MCNP results are higher; however, the trend reverses on the transporter outer surface. The difference can be attributed to the single-medium treatment of buildup factors in the PATH code, which lacks the capability of correcting for multiple media. Over-prediction or under-prediction could occur in the PATH calculation, depending on the selection of the medium used for the buildup factors.

The total dose rate on the WP outer surface from the MCNP calculation is 466.5 ± 2.4 rem/hr. This total includes 447.8 rem/hr from fuel gammas, 18.6 rem/hr from fuel neutrons, and 0.1 rem/hr from secondary gammas.

From the results presented in Table 17, the contribution from fuel gammas is a predominant component of the total dose rate on the WP outer surface, constituting 96% of the total. This contribution decreases to 71.4% on the transporter outer surface, because of neutron and gamma shielding provided for the transporter to achieve an appropriate gamma-to-neutron dose ratio for weight optimization purposes.

Table 17. MCNP Dose Rate Results for Homogenized Fuel Assembly Model

Radiation Component	Dose Rate (rem/hr)		
	Waste Package Outer Surface	Transporter Inner Surface	Transporter Outer Surface
Fuel Gamma	4.478E+02 (0.0054) ^a	2.917E+02 (0.0060)	1.499E-01 (0.0118)
Fuel Neutron	1.861E+01(0.0059)	1.644E+01(0.0064)	4.243E-02 (0.0160)
Secondary Gamma	1.020E-01(0.0147)	7.830E-02 (0.0156)	1.765E-02 (0.0143)
Total	4.665E+02 (0.0052)	3.082E+02 (0.0057)	2.098E-01(0.0091)

^a The value in parentheses denotes the fractional standard deviation for one-sigma uncertainty.

Table 18. Comparison of Gamma Dose Rate Results for Different Models

Model	Gamma Dose Rate (rem/hr)		
	Waste Package Outer Surface	Transporter Inner Surface	Transporter Outer Surface
PATH - Explicit Model ^a	3.728E+02	2.340E+02	1.979E-01
PATH - Homogenized Model	3.392E+02	2.571E+02	2.200E-01
MCNP- Homogenized Model	4.478E+02	2.917E+02	1.499E-01

^a Results at typical locations of 0⁰.

6.3 SPECIAL FUEL LOADING CONSIDERATIONS

The results presented in Tables 15, 16 and 17 are for the design basis fuel specification with the characteristics of 4% initial enrichment, 60 GWd/MTU burnup and 10 years cooling. This specification results in a heat generation rate of about 1.2 kW per fuel assembly, and covers 97% of the historical and projected PWR SNF inventory. The remaining 3% of the inventory include 1.6% of assemblies with thermal output in excess of 1.2 kW/assembly, and 1.4% of MOX fuel (see Table 8).

To accommodate fuel assemblies outside the design basis fuel specification, special fuel loading considerations are required. The options available include the following:

- Additional cooling time
- Selective fuel loading
- Administrative operational and access control

Additional cooling will reduce the thermal output with time until the assembly heat generation rate is below 1.2 kW/assembly. However, the additional cooling time would require more storage of hot assemblies on surface. The surface storage requirement will depend on the number of hot assemblies received at the repository.

To avoid the additional storage requirement, selective fuel loading may be used. There are four corner positions in the fuel assembly basket available for loading hot assemblies (i.e., assemblies with more than 1.2 kW/assembly) with minimal thermal performance impact. These positions include B2, B4, D2 and D4 (see Figure 2). Loading of the hot assemblies in these positions will mainly affect the dose rates at locations directly facing these assemblies such as the points at 45°. According to Table 17, File *preblend.dat* of CRWMS M&O 2000g, the maximum assembly heat generation rate loaded in the waste packages is ~2.0 kW/assembly. If a maximum heat assembly is loaded in one of the four designated positions (say, B2), the dose rate from this particular assembly will increase by approximately 70% as compared to the design basis fuel with 1.2 kW/assembly. Based on the results in Table 13, this increase poses no effect on the transporter shielding, as the gamma dose rate at 45° is still less than that at 0°. Therefore, this selective loading option is acceptable from a shielding standpoint.

Administrative operational and access control provides a means to deal with special or rare operational occurrences. In the event that three hot assemblies are loaded in the outer fuel basket positions and adjacent to each other, the resulting dose rate will exceed the design goal for the design basis fuel specification. Personnel access control may be imposed to restrict access to the operational areas such as the vicinity of the transporter where the design goal is exceeded. Other control measures such as reduction in occupancy time in an accessible area will also serve to bring down personnel exposures to be in line with the design goal. These administrative control practices are commonly used in the nuclear industry, provided that the occupational dose limits in 10CFR20.1201 such as 5 rem per year are met.

In summary, the design basis fuel specification for the waste packages provides coverage of 97% of the historical and projected PWR SNF population. With special considerations as discussed in

this section, the remaining 3% can be accommodated without imposing undue restrictions on the fuel loading scheme.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

7. REFERENCES

7.1 DOCUMENTS CITED

10 CFR 20. Energy: Standards for Protection Against Radiation. Readily available.

10 CFR 71. Energy: Packaging and Transportation of Radioactive Material. Readily available.

10 CFR 72. Energy: Licensing Requirements for the Independent Storage of Spent Nuclear Fuel and High-Level Radioactive Waste. Readily available.

10 CFR 961. Energy: Standard Contract for Disposal of Spent Nuclear Fuel and/or High-Level Radioactive Waste. Readily available.

ANSI/ANS-6.1.1-1977. *Neutron and Gamma-Ray Flux-to-Dose-Rate Factors*. La Grange Park, Illinois: American Nuclear Society. TIC: 239401.

ANSI/ANS-6.4-1997. *Nuclear Analysis and Design of Concrete Radiation Shielding for Nuclear Power Plants*. La Grange Park, Illinois: American Nuclear Society. TIC: 241065.

ANSI/ANS-6.4.3-1991. *American National Standard for Gamma-Ray Attenuation Coefficients and Buildup Factors for Engineering Materials*. La Grange Park, Illinois: American Nuclear Society. TIC: 7464.

Briesmeister, J.F., ed. 1997. *MCNP-A General Monte Carlo N-Particle Transport Code*. LA-12625-M, Version 4B. Los Alamos, New Mexico: Los Alamos National Laboratory. ACC: MOL.19980624.0328.

BSC (Bechtel SAIC Company) 2001a. *Design Basis Waste Input Assumptions for License Application*. TDR-CRW-SE-000014 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOV.20011129.0012.

BSC (Bechtel SAIC Company) 2001b. *Dose Rate Calculation for the 21-PWR UCF Waste Package*. CAL-UDC-NU-000002 REV 01. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010627.0027.

BSC (Bechtel SAIC Company) 2001c. *Dose Rate Calculation for the 44-BWR UCF Waste Package*. CAL-UDC-NU-000003 REV 01. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010629.0077.

BSC (Bechtel SAIC Company) 2001d. *Dose Rate Calculation for the Codisposal Waste Package of HLW Glass and the Melt-Dilute Al SNF*. CAL-DDC-NU-000004 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010730.0063.

BSC (Bechtel SAIC Company) 2001e. *Subsurface Shielding Source Term Specification Calculation*. CAL-WER-NU-000003 REV 00. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010423.0323.

Originator: AL Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

BSC (Bechtel SAIC Company) 2001f. *Uncanistered Spent Nuclear Fuel Disposal Container System Description Document*. SDD-UDC-SE-000001 REV 01 ICN 01. Las Vegas, Nevada: Bechtel SAIC Company. ACC: MOL.20010927.0070.

CRWMS M&O 1996a. *Software Code: PATH*. V 88A. PC. 30007-88A.

CRWMS M&O 1996b. *Source Terms for Design Basis Event Analyses*. BBA000000-01717-0200-00019 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.19970203.0121.

CRWMS M&O 1998a. *Evaluation of WP Transporter Neutron Shielding Materials*. BCAE00000-01717-0210-00002 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.19990119.0320.

CRWMS M&O 1998b. *Software Code: MCNP*. V 4B2LV. PC. 30033-4B2LV.

CRWMS M&O 1999a. *1999 Design Basis Waste Input Report for Commercial Spent Nuclear Fuel*. B00000000-01717-5700-00041 REV 01. Washington, D.C.: CRWMS M&O. ACC: MOV.19991217.0001.

CRWMS M&O 1999b. *BWR Source Term Generation and Evaluation*. BBAC00000-01717-0210-00006 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000113.0334.

CRWMS M&O 1999c. Reserved.

CRWMS M&O 1999d. *PWR Source Term Generation and Evaluation*. BBAC00000-01717-0210-00010 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000113.0333.

CRWMS M&O 1999e. *Shielding Characteristics of Various Materials on PWR Waste Packages*. BBAC00000-01717-0210-00008 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.19990218.0211.

CRWMS M&O 2000a. *Calculation of the Surface Dose Rates for the Single-CRM Naval SNF Waste Package*. CAL-VDC-NU-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000221.0710.

CRWMS M&O 2000b. *Design Analysis for UCF Waste Packages*. ANL-UDC-MD-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000526.0336.

CRWMS M&O 2000c. *Dose Rate Calculation for the DHLW/DOE SNF Codisposal Waste Package*. CAL-DDC-NU-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000223.0505.

CRWMS M&O 2000d. *Input Parameters for Thermal Modeling Using Conduction-Only Models*. CAL-NBS-TH-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001107.0365.

Originator: AS Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

CRWMS M&O 2000e. *Shielding Calculation for Emplacement Operations and Subsurface Layout*. CAL-SFS-NU-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20001026.0085.

CRWMS M&O 2000f. *Source Terms for HLW Glass Canisters*. CAL-MGR-NU-000002 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20000823.0004.

CRWMS M&O 2000g. *Waste Packages and Source Terms for the Commercial 1999 Design Basis Waste Streams*. CAL-MGR-MD-000001 REV 00. Las Vegas, Nevada: CRWMS M&O. MOL.20000214.0479.

CRWMS M&O 2001. *Classification of the MGR Waste Emplacement/Retrieval System*. ANL-WES-SE-000001 REV 01. Las Vegas, Nevada: CRWMS M&O. ACC: MOL.20010227.0016.

DOE (U.S. Department of Energy) 1992. *Characteristics of Potential Repository Wastes*. DOE/RW-0184-R1. Volume 1. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: HQO.19920827.0001.

DOE (U.S. Department of Energy) 2002. *Quality Assurance Requirements and Description*. DOE/RW-0333P, Rev. 12. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20020819.0387.

Naples, E.M. 1999. Thermal, Shielding, and Structural Information on the Naval Spent Nuclear Fuel (SNF) Canister. Letter from E.M. Naples (Department of the Navy) to D.C. Haught (DOE/YMSCO), August 6, 1999, with enclosures. ACC: MOL.19991001.0133.

NRC (U.S. Nuclear Regulatory Commission) 2000. *Standard Review Plan for Spent Fuel Dry Storage Facilities*. NUREG-1567. Washington, D.C.: U.S. Nuclear Regulatory Commission. TIC: 247929.

Reactor Experiments 1991. *Typical Element Analysis: 5% Boron-Polyethylene (Catalog No. 201) and Poly/Cast (5% Boron) (Catalog No. 259)*. Sunnyvale, California: Reactor Experiments. TIC: 242452.

Su, S.D.; Baylor, K.J.; and Engholm B.A. 1987. *PATH Gamma Shielding Code User's Manual*. GA-A167721, Rev. 1. San Diego, California: GA Technologies. TIC: 241215.

Weast, R.C., ed. 1985. *CRC Handbook of Chemistry and Physics*. 66th Edition. Boca Raton, Florida: CRC Press. TIC: 216054.

7.2 PROCEDURES USED

AP-3.12Q, Rev. 1, ICN 2. *Design Calculations and Analyses*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20020607.0013.

AP-3.13Q, Rev. 3, ICN 1. *Design Control*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20020925.0444.

AP-3.15Q, Rev. 3, ICN 4. *Managing Technical Product Inputs*. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20021105.0163.

Engineering Standard for Document/Component Numbering. Rev. 02. Washington, D.C.: U.S. Department of Energy, Office of Civilian Radioactive Waste Management. ACC: MOL.20020904.0194.

Originator: AA Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

8. ATTACHMENTS

This calculation document includes two attachments:

ATTACHMENT I Listing of Computer Files (1 page)

ATTACHMENT II One Compact Disk Containing All Files Listed in Attachment I
(1 of 1)

Originator: As Date: 12/09/02 Checker: GR Date: 12/09/02
Nuclear Engineering

ATTACHMENT I
LISTING OF COMPUTER FILES

This attachment lists the input and output file names for the PATH and MCNP calculations. All input and output files are stored on an electronic medium (compact disk) in ASCII format as part of this attachment.

<u>Date</u>	<u>Time</u>	<u>File Size</u>	<u>File Name</u>
11/09/00	10:47a	2,275	pwrwp00.inp
11/09/00	10:47a	19,364	pwrwp00.out
11/09/00	09:36a	5,977	pwrwp01b.inp
11/09/00	09:37a	45,678	pwrwp01b.out
11/09/00	09:56a	5,978	pwrwp02b.inp
11/09/00	09:56a	45,342	pwrwp02b.out
11/09/00	10:01a	5,978	pwrwp03b.inp
11/09/00	10:02a	46,372	pwrwp03b.out
01/12/01	08:23a	5,977	pwrwp04b.inp
01/12/01	08:24a	46,835	pwrwp04b.out
11/09/00	10:04a	5,978	pwrwp05b.inp
11/09/00	10:05a	45,615	pwrwp05b.out
01/12/01	08:27a	5,977	pwrwp06b.inp
01/12/01	08:28a	47,280	pwrwp06b.out
01/12/01	08:34a	5,977	pwrwp07b.inp
01/12/01	08:35a	47,410	pwrwp07b.out
01/12/01	08:38a	5,978	pwrwp08b.inp
01/12/01	08:39a	46,759	pwrwp08b.out
01/12/01	11:19a	6,756	pwrwp09b.inp
01/12/01	11:20a	49,469	pwrwp09b.out
01/12/01	11:21a	6,756	pwrwp10b.inp
01/12/01	11:22a	48,285	pwrwp10b.out
09/05/02	03:56p	7,455	wpgamma0
09/05/02	07:17p	69,538	wpgamma0.out
09/05/02	01:44p	8,192	wpneut0
09/05/02	03:26p	108,559	wpneut0.out

Originator: AS
Nuclear Engineering

Date: 12/09/02

Checker: GR

Date: 12/09/02

OFFICE OF CIVILIAN RADIOACTIVE WASTE MANAGEMENT

1. QA: QA

SPECIAL INSTRUCTION SHEET

Page: 1 of 1

Complete Only Applicable Items

file list
12-16-02 mfc

This is a placeholder page for records that cannot be scanned.

2. Record Date 12/09/2002		3. Accession Number <i>ATT TO:</i> <i>MOL.20021216.0076</i>	
4. Author Name(s) STEVE SU		5. Author Organization <i>N/A</i>	
6. Title/Description SUBSURFACE SHIELDING SOURCE TERM SPECIFICATION CALCULATION			
7. Document Number(s) 000-00C-WER0-00100-000-00A			8. Version Designator A
9. Document Type DATA		10. Medium CD-ROM	
11. Access Control Code PUB			
12. Traceability Designator DC#33767			

13. Comments
THIS IS A SPECIAL PROCESS CD-ROM AS PART OF ATTACHMENT 1 (1 OF 1).

THIS DOCUMENT CONTAINS
AN ELECTRONIC ATTACHMENT

BSC

Engineering Change Notice

1. QA: QA
2. Page 1 of 1

Complete only applicable items.

000-00C-WER0-00100-000-00A-ECN1

3. Document Identifier: 000-00C-WER0-00100-000-00A	4. Rev.: 00A	5. Title: Subsurface Shielding Source Term Specification Calculation	6. ECN: 1
---	-----------------	---	--------------

7. Reason for Change:
Per LP-3.12Q-BSC Design Calculations and Analyses Section 5.1 [2] c,

“The decision of the DEM, PCSA Manager, Criticality Manager, or PCA Manager to issue calculations or analyses with a “committed” status will be based on an experienced assessment of the likelihood that the results of the calculation or analysis will change, and the degree of impact those changes will have on designs that support the regulatory submittals or procurement activities, based on the design’s bounding conservatism.”

the status designation of *Subsurface Shielding Source Term Specification Calculation* (000-00C-WER0-00100-000-00A) can be changed to “Committed” as the results are not expected to change in such a manner that will affect support of regulatory submittals.

8. Supersedes Change Document:	<input type="checkbox"/> Yes	If, Yes, Change Doc.: _____	<input checked="" type="checkbox"/> No
--------------------------------	------------------------------	-----------------------------	--

9. Change Impact:			
Inputs Changed:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Results Impacted:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No
Assumptions Changed:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No	Design Impacted:	<input type="checkbox"/> Yes <input checked="" type="checkbox"/> No

10. Description of Change: (Address any “Yes” answers)
Add a "Committed" option in Block 7 on the cover sheet and change the "Document Status Designation" from Preliminary to "Committed". Block 7 on the cover sheet should read as follows:

7. Document Status Designation <input type="checkbox"/> Preliminary <input checked="" type="checkbox"/> Committed <input type="checkbox"/> Final <input type="checkbox"/> Canceled

11. Originator: (Print/Sign/Date) Dorin Musat	<i>Dorin Musat</i>	<i>8/12/2005</i>
Checker: (Print/Sign/Date) YuChien Yuan	<i>YuChien Yuan</i>	<i>8/12/2005</i>
Approved: (Print/Sign/Date) Dave Darling	<i>DB Darling</i>	<i>8/12/05</i>